



BAY AREA AIR QUALITY

MANAGEMENT

DISTRICT

ALAMEDA COUNTY

Tom Bates (Chairperson) Scott Haggerty Jennifer Hosterman Nate Miley

CONTRA COSTA COUNTY

John Gioia (Vice-Chair) David Hudson Mark Ross Gayle B. Uilkema

MARIN COUNTY Harold C. Brown, Jr.

NAPA COUNTY Brad Wagenknecht

SAN FRANCISCO COUNTY

John Avalos Eric Mar Edwin M. Lee

SAN MATEO COUNTY

Carol Klatt Carole Groom

SANTA CLARA COUNTY

Susan Garner Ash Kalra (Secretary) Liz Kniss Ken Yeager

SOLANO COUNTY James Spering

SONOMA COUNTY Susan Gorin Shirlee Zane

Jack P. Broadbent EXECUTIVE OFFICER/APCO

Ms. Deborah Jordan
Director, Air Management Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

Dear Ms. Jordan:

This is to advise you that the Bay Area Air Quality Management District is issuing a minor revision to the Major Facility Review Permit for the following facility.

Facility	Facility Name	Application	Permit Engineer	City	County
B1180	Calpine Gilroy Cogen, L.P. & Gilroy Energy Center, LLC	22302	B. Lusher	Gilroy	Santa Clara

The purpose of this minor permit revision is to allow the installation of new dry low NOx combustors on S-100 to meet Regulation 9, Rule 9 requirements.

An additional applicable requirement was added to Table IV-B, S-100, Gas Turbine, since the document was sent to EPA for review. 40 CFR Part 60, Subpart GG, Section 60.334(c) was added to the applicable requirements, since this citation will apply to S-100 after the installation of the Dry Low NOx combustors. This citation was also added to Table VII-B, S-100, as a monitoring requirement to demonstrate compliance with 40 CFR Part 60.332(a)(1) (NOx limit).

The facility contact was changed on the cover of the Title V permit from Maria Barroso, Compliance Manager, to Michael Fees, Plant Manager. The BAAQMD contact was changed from Allen Chiu to Brian Lusher. Phone numbers for the plant contacts were updated. Table VII-B for S-100 was changed to reflect that the monitoring Condition No. 21961 Part IX-E requires steam injection monitoring to demonstrate compliance with the NOx limit contained in Condition No. 21961 Part IX-C. These changes are administrative amendments as defined in BAAQMD Regulation 2-6-201.

The District has decided to issue the permit incorporating the proposed minor revision. The final permit can be viewed and/or downloaded on the BAAQMD website at http://www.baaqmd.gov/Divisions/Engineering/Title-V-Permit-Programs/Title-V-Permits.aspx. We will also send the final permit via the Electronic Permit Submittal System. If you have any questions regarding this permit, please call Barry Young, Air Quality Engineering Manager, at: (415) 749-4721.

Sincerely yours,

Jack P. Broadbent	
Executive Officer/Air Pollution Control Office	r

JPB:BFB:BKL